

INSTALLATION INSTRUCTIONS FOR

## Remote Control Unit

Catalogue Number HE8407


PLEASE RETAIN THIS LEAFLET

### CONTROLLER HE8407

The remote control switch box or HE8407 is for use with the 3 kW and 4.5 kW Screen Zone curtain heaters HE7402, 7420 & 8320, and the 6 kW Screen Zone curtain heater HE7426.

The unit comprises of one 32A double pole and two 20A switches in a surface mounting box, 166 mm x 86 mm x 40 mm deep.

The unit is supplied wired for use.



In the interest of progress the Company right to vary specifications from time to time without notice. The material listed is offered subject to the Company's General Conditions of Sale, a copy of which may be obtained upon request.

All wiring connected to the heater switches and 3-way terminal block should be removed and connections between the 4-way terminal block and the remote switch made as shown below. The neutral is not switched. A suitable double pole isolation switch should be incorporated in the circuit.

For safety reasons, a sound earth connection must always be made to the unit before use.

